KIMMCO-ISOVER
Duct Insulation (KDI)



KIMMCO ISOVER
SAINT-GOBAIN

About Us

Alghanim Industries and French construction giant Saint-Gobain ISOVER join forces together after the recent launch of their new stone wool plant in Yanbu Saudi Arabia and the integration of KIMMCO in Kuwait.

With a 40 year track record in manufacturing, technology and supply of insulation materials and solutions to the Middle East markets, KIMMCO and Saint-Gobain ISOVER now offer their full range of glass wool and stone wool products and solutions under the brand KIMMCO-ISOVER.

Alghanim INDUSTRIES

- Alghanim Industries is one of the largest privately –owned companies in the Gulf region
- A heritage of over 100 years as a successful commercial enterprise in the Gulf region
- Operations in over 40 countries and employing
- Over 14,000 employees
- A multi-billion dollar company with more than 30 businesses.

SAINT-GOBAIN

World leader in sustainable habitat and construction market.

Saint-Gobain designs, manufactures and distributes material and solution which are key ingredients in the wellbeing of each of us and the future of all.

- Founded in 1665
- Nearly 179,000 employees
- Operates in 67 countries
- Close to 400 patents filed each year

KIMMCO-ISOVER Duct Insulation (KDI)

APPLICATIONS

External insulation of rectangular and circular air ducting and air handling equipment.

DESCRIPTION

KDI is in the form of flexible rolls, semi-rigid and rigid slabs manufactured from stable glass fibers bonded with thermo-setting resins, and free from coarse fibers and shot. Easy to handle and cut to fit rectangular ducts and air handling equipment.

Facings

KDI is available unfaced or with a glass reinforced aluminum foil/kraft laminate facing (FSK) which combines a pleasing appearance with excellent vapor resistance.

Standard Dimensions

Availability	Thickness (mm)	Width (m)	Length (m)
Rolls	25, 40, 50, 75, 100	0.4, 0.6, 1.0, 1.2	10 to 45 according to the thickness & density
Slabs	25, 40, 50, 75, 100	1.2	1.0 to 2.4

Other dimension and/or thickness upon request

Nominal Density

KDI	kg/m^3	Lbs/ft^3	Availability
10	10	0.625	Rolls
12	12	0.75	Rolls
16	16	1	Rolls
18	18	1.125	Rolls
20	20	1.25	Rolls
24	24	1.5	Rolls or Slabs
32	32	2	Rolls* or Slabs
36	36	2.25	Rolls* or Slabs
48	48	3	Rolls* or Slabs
64	64	4	Slabs
72	72	4.5	Slabs
80	80	5	Slabs
96	96	6	Slabs

*Rolls according to the thickness

PERFORMANCE

Operating Temperature

Fibre upto 232 °C (450 °F)

Facing 100 °C (212 °F)

Permanence

KDI has a high resistance to accident damage from knocks and handling during installation and maintenance. Dimensionally stable under varying conditions of temperature and humidity, rot proof, odourless, non-hygroscopic and will not sustain vermin or fungus.

Combustibility

Base fibers are non combustible when tested in accordance with BS 476 (part 4), ASTM E136.

Surface Burning Characteristics

When tested as per ASTM E84 / NFPA 255 / UL 723.

Flame spread index : Not over 25
Smoke developed index : Not over 50

Moisture Absorption

Less than 1% by volume when tested in accordance with ASTM C1104.

KDI does not absorb moisture from the ambient air nor water by capillary attraction. Only water under pressure can enter the insulation products, but that will quickly dry out owing to the material's open cell structure.

FSK faced KDI comply with ASTM E 96 Desiccant Method. Permeance not to exceed 0.02 perms (Federal Standard HH-B-100 B Type 1- superseded by ASTM C1136)

NON TOXIC

KDI is not hazardous to health (See KIMCO-ISOVER MSDS)

No Corrosion

Does not cause or accelerate corrosion of steel, copper or aluminum.

Thermal Conductivity

The low thermal conductivity of fiberglass products is due to the fact that they consist of more than 95% air which is trapped and kept stationary by the thin fibers below test values are tested as per ASTM C518.

Mean Temperature °F	Thermal Conductivity in Btu.in/ft²h.F for the following densities in lbs/ft³												
	0.625	**0.750**	**1.000**	**1.125**	**1.250**	**1.500**	**1.875**	**2.000**	**2.250**	**3.000**	**3.750**	**4.000**	**4.500**
32	0.26	0.25	0.23	0.23	0.22	0.21	0.21	0.20	0.20	0.20	0.21	0.21	0.21
50	0.28	0.27	0.25	0.24	0.23	0.22	0.22	0.22	0.21	0.21	0.21	0.23	0.23
77	0.31	0.29	0.27	0.26	0.25	0.24	0.23	0.23	0.22	0.22	0.23	0.23	0.23
122	0.38	0.34	0.31	0.30	0.28	0.27	0.26	0.25	0.25	0.24	0.24	0.24	0.24
167	0.45	0.41	0.35	0.34	0.32	0.30	0.28	0.27	0.27	0.26	0.26	0.26	0.26
212	0.51	0.45	0.40	0.37	0.36	0.33	0.31	0.30	0.30	0.29	0.29	0.29	0.29

Mean Temperature °C	Thermal Conductivity in W/m.K for the following densities in kg/m³												
	10	**12**	**16**	**18**	**20**	**24**	**30**	**32**	**36**	**48**	**60**	**64**	**72**
0	0.038	0.036	0.034	0.033	0.032	0.031	0.030	0.030	0.029	0.029	0.030	0.030	0.030
10	0.040	0.038	0.036	0.035	0.034	0.032	0.032	0.031	0.030	0.030	0.031	0.031	0.031
25	0.044	0.041	0.039	0.038	0.036	0.035	0.034	0.033	0.032	0.031	0.032	0.032	0.032
50	0.055	0.048	0.044	0.043	0.041	0.039	0.037	0.037	0.036	0.035	0.036	0.036	0.036
75	0.064	0.059	0.051	0.048	0.046	0.043	0.041	0.040	0.039	0.037	0.038	0.038	0.038
100	0.074	0.065	0.057	0.053	0.051	0.047	0.045	0.044	0.043	0.041	0.042	0.043	0.043

These are typical values subject to normal manufacturing and testing variances

CONFORMITY TO STANDARDS

American Standards		British Standards	ISO	Other Standards
C 165	C 1045	BS 476 (part 4, 6 & 7)	8301	UL 723
C 167	C 1101/ 1101M	BS 874	8302	NFPA 255 NFPA 90A & 90B
C 168	C 1104 / 1104M	BS 2972	9229	NAIMA Standards
C 177	C 1136 (Type 1 & 2)	BS 3533	9291	ASHRAE 90.1 & 90.2 requirements
C 303	C 1290 (Type 3)	BS 3958 (part 5),		SMACNA Standards
C 411	C1304	BS 5422		F.S. HH-B-100B (Type 1) superseded by ASTM C1136) F.S. HH-1-521F(superseded by ASTM C665) F.S. HH-1-558B(superseded by ASTM C612)
C553	C1338	BS 5643		
C 612(Type I & II	E84	BS 6676 (Part 1)		
C 665 & 13.8 & 13.9	E96			
C 686	E136			German Standards DIN 18165, DIN 52612

ONLINE CERTIFICATIONS DIRECTORY

BKNV.R9703
Batts and Blankets

Page Bottom

Batts and Blankets

See General Information for Batts and Blankets

KUWAIT INSULATING MATERIAL MFG CO
BEHIND MINA ABDULLAH POLICE STATION
P.O.BOX 10042
65451 SHUAIBA, KUWAIT

R9703

Glass fiber batts and blankets with and without facings on one surface.

The following products are eligible to bear the Laboratories Classification Marking incorporating the designation "FHC 25/50" instead of the individual Surface Burning Characteristic values for flame spread and smoke developed:

Unfaced Blankets

Aluminum Foil Faced Blankets

Foil-Scrim-Kraft Faced Blankets

Black Glass Fabric Faced Blankets

Glass fiber batts and blankets with and without facings on one surface and Rock wool batts and blankets without facings.

	Basic Blanket	Foil-Scrim Kraft Facing	Vinyl Film Facing	Aluminum Foil Facing	Rock Wool Blanket	Black Glass Fabric
Flame Spread	15	15	25	15	0	25
Smoke Developed	0	0	80-105	0	0	5

	Basic Blanket
Flame Spread	0
Smoke Developed	0

Last Updated on 2015-07-02

Questions? Print this page Terms of Use Page Top

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".

Duct Wrap Installation Procedures

Step 1

Wear Protection tools (dust mask & hand gloves)



Step 2

Ensure that air duct service is free of oil, grease, or water and tightly sealed at all the joints.



Step 3

Measure the dimension of the duct. Width of insulation needed shall be

Width = (2 x height)+ (2 x width) +8 x thickness of insulation



Step 4

With the foil side of the insulation facing up, Wrap the insulation around the duct ensuring that the ends are butted tightly together.



Step 5

Tape every joint completely with pressure sensitive aluminum tape along the seam where insulation butts together.

Important Remarks:

- Self-adhesive aluminum foil tapes should, ideally, be reinforced and a minimum 75mm in width and have a thickness of at least 30 microns to ensure adequate adhesion
- For circular and rectangular ductwork the use of tie wires, lacing wire and clips are the most common methods.
- It is not recommended that an overlap method of installation is used. The overlap of material causes greater stress to be placed on the self-adhesive aluminum foil tape. This can result in delamination, breaking the vapor barrier provided by the tape.
- Self-adhesive aluminum foil tape should not be used as a mechanical fixing. Its function is to provide a vapor barrier between the foil surface and the separate foil faced insulation.
- Rectangular duct of 600mm width and greater shall be tighten with metal seam to avoid insulation sagging

Commitment to Quality

Properties of KIMMCO-ISOVER Products

- Excellent thermal performance
- Superior acoustic performance
- Excellent fire safety
- Environmentally friendly: made from abundantly available, non-strategic materials.
- Suitable for a wide variety of applications (flexible, semi-rigid, rigid and extra-rigid)
- Address a variety of performance requirements (wide range of facing materials)
- Easy to cut and install, minimum wastage on-site
- Comparatively light in weight
- Dimensionally stable
- No sagging or settling
- Complies with international standards

Further, we are members of the following industry associations:

- Emirates Green Building Council (EGBC)
- Kuwait Green Building Council (KGBC)
- Qatar Green Building Council (QGBC)
- Singapore Green Building Council (SGBC)
- MASDAR (The Future Build)
- Middle East Mineral wool Insulation Manufacturers Association (MEMIMA)

Our Commitment to the Environment

KIMMCO-ISOVER was selected as the sole insulation supplier and official collaborator with MASDAR city, the world's first zero-carbon, zero-waste city, in Abu Dhabi. We have a strong commitment to the environment, health and safety of our people, and surrounding communities, and actively collaborate with local and international environmental agencies. Further, KIMMCO-ISOVER products help developers achieve green building rating certifications such as LEED, Estidama and QSAS

Our Product Listing & Certification

- DCL
- UL
- CE
- BV
- ABS

Our Commitment to Quality

we have a strong commitment to quality, as recognized by our certification by international bodies such as ISO.

KIMMCO ISOVER
SAINT-GOBAIN

www.kimmco-isover.com

11/2018